

DIRECT



LISTING REPORT - MANUFACTURING
Issued: Jul 1 2008 9:57AM

Inspection Tests And Evaluation Of
Flame Seal Products - FX100-TB (17330)

RENDERED TO
Flame Seal Products Inc.
4025 Willowband Blvd.
Suite 310
Houston, TX 77025

GENERAL: This Report gives the results of the inspection, tests and evaluation of the above for compliance with applicable requirements of the following standards: UL 1715 (2008)

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. To verify a listing, call 888-347-6478, or check our searchable online Directory of Listed Products at www.intertek.com.

Report prepared for: Tammy Anderson (Intertek ETL SEMKO) on 7/1/2008 2:52:21 PM

DIRECT



CORRELATION FOR MULTIPLE LISTINGS

This information is only available to the applicant.

Report prepared for: Tammy Anderson (Intertek ETL SEMKO) on 7/1/2008 2:52:21 PM

DIRECT



PRODUCT DESCRIPTION

Product Covered:

Flame Seal Products - FX100-TB

Product Description:

PRODUCT COVERED

CERTIFIED PRODUCT: FX100-TB

CERTIFICATION PROPERTY: Flammability and Thermal Barrier

PRODUCT DESCRIPTION

FX100-TB: An intumescent, water based, non-toxic, 2-part (FX 100-TB base and T50-TB Curing Agent) liquid Fire Retardant Coating, for use as a Thermal Barrier and/or Ignition Barrier on Spray Applied Polyurethane Foam Insulation.

<u>Attribute</u>	<u>Value</u>
Architecture Code	07800 Fire and Smoke Protection
Architecture Subcode	07810 Applied Fireproofing
Listed or Inspected	LISTED
Report Number	3147158SAT-007 QCM
Criteria	UL 1715 (2008)
Intertek Services	Certification
Listing Section	OTHER PRODUCTS
Verification Testing	YES

Report prepared for: Tammy Anderson (Intertek ETL SEMKO) on 7/1/2008 2:52:12 PM



AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the Product Covered described below herein when made in accordance with the authorized Listing Report, including Manufacturing/Machining Specifications, and under conditions set forth in the Certification Agreement and Listing Report, including Manufacturing/Machining Specifications. This authorization also applies to the Multiple Listee model(s) identified on the correlation page of the Listing Report.

Client Number: 61167

Report Number: 3147158SAT-007 QCM

Evaluation Center:

Intertek (Elmendorf)

Applicant/Basic Listee:

Flame Seal Products Inc.
4025 Willowbend Blvd.
Suite 310
Houston, TX 77025

Mike Kiser
713-668-4291
713-668-1724

Product Covered:

Flame Seal Products - FX100-TB

Testing Standards:

UL 1715 (2008)

This document is the property of Intertek Testing Services and is not transferable. Only the Applicant may reproduce this document. The Certification Mark(s) may be applied only at the above noted location of the Party Authorized to Apply the Mark(s).



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Report prepared for: Tammy Anderson (Intertek ETL SEMKO) on 7/1/2008 2:52:12 PM

Listing Section(s):

OTHER PRODUCTS

Description:

PRODUCT COVERED

CERTIFIED PRODUCT: FX100-TB
CERTIFICATION PROPERTY: Flammability and Thermal Barrier

PRODUCT DESCRIPTION

FX100-TB: An intumescent, water based, non-toxic, 2-part (FX 100-TB base and T50-TB Curing Agent) liquid Fire Retardant Coating, for use as a Thermal Barrier and/or Ignition Barrier on Spray Applied Polyurethane Foam Insulation.

Report prepared for: Tammy Anderson (Intertek ETL SEMKO) on 7/1/2008 2:52:12 PM

**Party(s) Authorized by
Manufacturer To Apply Mark:**
None

**Party(s) Authorized by Other Parties To Apply
Mark:**
None